

TOPPING DRAIN 2023
Township of Adelaide Metcalfe

ADDENDUM NO. 1

Our Job No. 221194

Date: May 21, 2024

**PLEASE INDICATE RECEIPT OF THIS ADDENDUM BY
SIGNING BELOW AND EMAILING BACK TO:**

aneely@adelaidemetcalfe.on.ca

Spriet Associates armin@spriet.on.ca

**ALSO, A COPY OF THIS ADDENDUM IS TO BE ATTACHED TO THE TENDER WITH
SUBMITTAL**

I hereby acknowledge receipt of Addendum No. 1

NAME (Please Print)

Company

- 1/ The wye at Main Drain Sta. 1+167 shall be a 250mm x 450mm wye not a 250mm x 375mm wye as shown on page 3 of the drawings.
- 2/ The H.B.C.B. at Branch "A" WASCOB Sta. 0+289 shall be 300mm H.B.C.B. not a 250mm H.B.C.B. as shown on page 3 of the drawings.

Sincerely,



Tyler Foslett, Junior Technologist
SPRIET ASSOCIATES LONDON LIMITED